

No : C – 194/2019/01

O/o Station Officer

Fire and Rescue Station

Pattimattom, Date : 01.07.2019


CERTIFICATE OF EXEMPTION FROM NOC

The application for certificate of exemption from NOC submitted to this office by The Manager, Darussalam Public School, Kumarapuram P O, Pallikkarahas been verified by me on 01.07.2019, regarding the construction of a building in survey no - 267/5;;267/8; 281/3-2;267/5;267/3;281/4,267/4,267/2,280/1, Kunnathunadu Village, Kunnathunadu Taluk, Ernakulum Dist under the jurisdiction of Kunnathunadu Gramapanchayathu.

The height of the Educational buildings are building no : /400(G) ,School building no : /400A (G+1) , School building no : /400 B(G+2) are 7.75M, 9.85 M, 12.90M respectively, and the plinth areas are 458.52m²,695.78m² and 2023m², Which are less than 15 meter and 1000m respectively and found to be exempted from Fire NOC as per KMBR/KPBR vide Gov Orders F2 – 102/19 Home. dtd 02/04/2019 GP(P) No:81/2017/LSGD dtd 31/10/2017 and GO (P) No: 82/2017/LSGD dtd 31/10/2017 Under the "Ease of doing Business " Policy

Hence it is certificate that the aforesaid building is exempted from acquiring NOC from Fire and rescue Services department as per the conditions prescribed the orders cited above.




Station Officer
FIRE & RESCUE STATION
PATTIMATTAM

Pattimattom