


**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No. PHC/64/2026


Dated: 30.07.2026


It is certified that an inspection team headed by Bindu K Issac, Health Inspector, Primary Health Centre, Kumarapuram, Kunnathunadu Grama Panchayath inspected Darusslam Public School, Kumarapuram, Ernakulam (Dt) on 24.07.2026 and on the basis of Water Test Report (Attached) bearing No:ANK/735/06/2026-27 dt 19.06.2026, Quality Control Sub District Laboratory, Ankamaly, Ernakulam, Kerala Water Authority, Govt. of Kerala (PHED Lab) certified that Darusslam Public School has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Kerala State Government.


This certificate is valid till 29.07.2027


HEALTH INSPECTOR
P.H.C. Kumarapuram
Kunnathunadu Grama Panchayath

To
The Principal
Darusslam Public School,
Kumarapuram,
Ernakulam(Dt)


PRINCIPAL
DARUSSALAM PUBLIC SCHOOL
(Affiliated to CBSE No. 930984)
Pallikkara, Kumarapuram P.O
Aluva, Ernakulam - 683 565




CHAIRMAN
DARUSSALAM PUBLIC SCHOOL
(Affiliated to CBSE No. 930984)
Pallikkara, Kumarapuram. P.O.,
Aluva, Ernakulam - 683 565



KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LAB, ANKAMALY (NABL RECOGNIZED)

WATER TEST REPORT

Report Issue Date: 19.06.2026

DARUSSALAM PUBLIC SCHOOL PALLIKKARA, KUMARAPURAM P.O			Date of Receipt of Payment	10.06.2026	
			Date of Sample received	11.06.2026	
			Sample Given by	MO FHC KUMARAPURAM	
			Sample Code	ANK/735/06/2026	
			Sample Name	DRINKING WATER	
			Sample Condition	Fit For Analysis	
			Source of Sample	WELL	
			Sample Quantity	2 Litre	
			Test performing dates : From: 15.06.2026 To: 15.06.2026		
Sl.No	Characteristics	Unit	Test Methods	Acceptable Limit as per IS 10500-2012	Result
1	Turbidity	NTU	IS 3025 (Part10)-1984(Reaffirmed 2017)	1.0	0.95
2	pH at 25 ⁰ C	-	IS 3025 (Part 11)2022	6.5 to 8.5	6.6
3	Electrical Conductivity	micromhos/cm	IS 3025(part14)-2013(Reaffirmed 2019)	-	95
4	Total Hardness (as CaCO3)	mg/L	IS 3025 (Part21)-2009(Reaffirmed 2019)	200	92
5	Chloride (as Cl)	mg/L	IS 3025 (Part 32)-1988(Reaffirmed 2019)	250	10.6
6	Iron (as Fe)	mg/L	IS 3025(part 53) - 2003(Reaffirmed 2019)	1	0.2
7	Nitrate (as NO3)	mg/L	APHA 4500-NO3- B 2012	45	25

Remarks :

NB-1) The result stated above related only to the sample(s) submitted for testing by the customer

2) The samples retain for 15 days from the end date of analysis

3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

End of Report



Analysed By

[Signature]

FATHIMA FAIROOS

Technical Manager

KWA/QCSDL/ANK/F 21

Issue Date : 02.07.2021

Rev No:02

Rev.Date :12/07/2023

PRINCIPAL
DARUSSALAM PUBLIC SCHOOL
(Affiliated to CBSE No. 930984)
Pallikkara, Kumarapuram P.O
Aluva, Ernakulam - 683 565



CHAIRMAN

DARUSSALAM PUBLIC SCHOOL
(Affiliated to CBSE No. 930984)
Pallikkara, Kumarapuram P.O
Aluva, Ernakulam - 683 565



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, ANKAMALY

WATER ANALYSIS REPORT

REPORT NO : ANK/735/06/2026-27

Report Issue Date: 19.06.2026

Customer Name & Address DARUSSALAM PUBLIC SCHOOL PALLIKKARA, KUMARAPURAM P.O	Date of Receipt of Payment	10.06.2026
	Date of Sample received	11.06.2026
	Sample Given by	MO PHC KUMARAPURAM
	Sample Code	ANK/BC 122/06/26
	Sample Name	DRINKING WATER
	Source of Sample	WELL
	Sample Quantity	200ml
Test performing dates : From: 11.06.2026 To: 13.06.2026		

Sl. No.	Parameter	Acceptable Limit as per IS 10500-2012	Test Method	Result
1	Total Coliform	Shall not be Detected/100ml	IS15185-2016 (Reaffirmed 2021)	NIL
2	E-Coli	Shall not be Detected/100ml	IS15185-2016 (Reaffirmed 2021)	NIL

Remarks:-

NB.-The result stated above related only to the sample(s) submitted for testing by the customer. The test certificate shall not be reproduced except in full without the written approval of the Laboratory

End of Report



Authorized By

JASTHI A KARIM
Bacteriologist

KWA QCSDL ANK 01-2022	Issue Date : 01.06.2022
Rev.No:Nil	Rev.Date:Nil
	Page 1 of 1

PRINCIPAL
DARUSSALAM PUBLIC SCHOOL
(Affiliated to CBSE No. 930984)
Pallikkara, Kumarapuram P.O
Aluva, Ernakulam - 683 565



CHAIRMAN
DARUSSALAM PUBLIC SCHOOL
(Affiliated to CBSE No. 930984)
Pallikkara, Kumarapuram P.O.,
Aluva, Ernakulam - 683 565

